



ADDITIONAL INFORMATION

Reference CB005.3.12.001 - LP – Supply 2

Contract title: “Supply of laboratory furniture for the purposes and functioning of the scientific laboratories of the BLUE GROWTH Research centre at “Prof. D-r Asen Zlatarov” University of Burgas”

According to p. 5 of Volume 1, Section 1: Instructions to Tenderers of the tender documentation herewith the Contracting Authority provides the following additional information and clarifications concerning questions received within the deadline specified in the tender dossier:

1. Laboratory island –8 pcs.

Question 1: *How many water trap should there be on the Laboratory Island?*

Additional information to question 1: *As provided in Annex II+III: Technical specifications + Technical offer traps for the laboratory islands are required. The minimum number of traps and water taps required is 2 per island.*

Question 2: *Should there be edges on laboratory worktops prevent spillage of liquids?*

Additional information to question 2: *Edges alongside the sink are required, while recommendable around the whole worktop.*

2. Laboratory worktop – 26 m.

Question 3: *What depth should be the laboratory worktops 600 mm, 650 mm, 700 mm, 750 mm, 800 mm?*

Additional information to question 3: *Recommendable depth of the worktop is as follows:*

- 1.5 m – 900 mm;
- 24.5 m – 800 mm.

Question 4: *What must be the height of laboratory worktops 750 mm, 800 mm, 850 mm, 900 mm?*

Additional information to question 4: *Recommendable height of worktop – 850 mm.*





Question 5: *Should there be edges on laboratory worktops prevent spillage of liquids?*

Additional information to question 5: *Edges around the worktop are recommendable.*

4. Fume hoods – 7 pcs.

Question 6: *Are the dimensions of the Fume Hoods allowed to be:*

-Gross size: 2100x900x2200mm; Dimensions of the chamber: 1800x700x1100mm? or

-Gross size: 1800x900x2200mm; Dimensions of the chamber: 1500x700x1100mm?

Additional information to question 6: *The minimum requirements for the fume hoods are provided in Annex II+III: Technical specifications + Technical offer, i.e. gross size: 1800x680x2200 mm and dimensions of the chamber: 1715x600x900 mm. Thus, the first suggested option meets the requirements of the technical specification.*

Question 7: *What is the length of the ventilation route?*

Additional information to question 7: *The ventilation route for the two of the fume hoods is 7 m., while for the rest 5 units is 5 m.*

Question 8: *How many bends does the ventilation path have?*

Additional information to question 8: *Each one of the ventilation routes has 2 bends.*

Question 9: *Are the fans for roof mounting or for indoor installation?*

Additional information to question 9: *The fans shall be mounted on the roof.*

5. Metal cupboard – 4 pcs.

Question 10: *What are the sizes?*

Additional information to question 10: *Minimum dimensions required: 1000x400x1800 mm.*

6. Desk– 8 pcs.

Question 11: *What are the sizes?*

Additional information to question 11: *Minimum dimensions required: 750x1200x600 mm (+/-50 mm).*

